

Life cycle cost analysis for AHUs in hot and humid climates




Mr Arvind Singh
Director
FläktGroup

Demand to Reduce Energy Consumption

- Floor area in the buildings sector worldwide is expected to increase 75% between 2020 and 2050, of which 80% would be in emerging markets and developing economies.
- In this regard, India is uniquely placed with three-quarters of the buildings, infrastructure and industrial capacity of India in 2050 yet to be built.
- Despite this demand growth the total Co2 emissions from the buildings sector need to decline by more than 95% by 2050. This would translate to more than 85% of buildings complying with zero-carbon-ready building energy codes by 2050.
- In addition, Air side load contributes approximately to 14% of the overall Building energy load. Under this scenario, an efficient airside in the HVAC sector becomes ever-important to ensure meeting these requirements while maintaining a high level of IAQ.

Buildings and their HVAC systems

- A typical HVAC account is generally responsible for approx. 40% of total building energy consumption.
- Essences involved in mechanical ventilation
- Indispensable in new and refurbished airtight buildings to ensure IAQ
- Air handling units have a major impact on energy consumption Air transport and heat recovery



Essential to Save Energy

Energy sources:

- Limited traditional energy sources (oil, gas, coal etc.)
- Increase of energy consumption (China, India)
- Increase of energy prices

The Environment:


- Global warming, CO₂
- Emissions, pollution

Legislation:

- Global and regional regulations/ restrictions



Product Certification - Importance of 3rd party



Selection Program Control*

Comparison of measured and
declared values



Device test in an independent
accredited laboratory



CERTIFY ALL



Audit of production plants



Compliance



Independent certification body

More than 40 certification programs

A team of 60 highly qualified HVAC-R specialists and auditors

Cooperation with almost 30 accredited labs throughout Europe

AHU Certification Program



EN 1886

Mechanical properties

- Enclosure tightness
- Tightness of the filter Bypass
- Thermal transmittance
- Influence of thermal bridges
- Sound insulation

EN 13053

Performance characteristics

- Flow – Available pressure – Consumption
- Electrical power
- Sound power level (per channel)
- Sound power level (surroundings)
- Heating capacity
- Cooling capacity
- Heat recovery
- Water side pressure drop

cold climate



hot and humid climate



Reference parameters for energy classes

- 1) Air velocity
- 2) Heat recovery efficiency
- 3) Flow resistance
- 4) Fan efficiency


CLASS	All Units	Units for full or partial outdoor air at design winter temperature $\leq 9^{\circ}\text{C}$		Fan Efficiency Grade $\text{NG}_{\text{ref-class}} [-]$
	Velocity $v_{\text{class}} [\text{m/s}]$	Heat recovery system $\eta_{\text{class}} [\%]$	$\Delta p_{\text{class}} [\text{Pa}]$	
A+ / A+C / A+↑	1.4	83	250	64
A / A-C / A↑	1.6	78	230	62
B / B-C / B↑	1.8	73	210	60
C / C-C / C↑	2.0	68	190	57
D / D-C / D↑	2.2	63	170	52
E / E-C / E↑	No calculation required			No requirement

Table 6: Table for energy efficiency calculations

26/09/24
The lowest classes E, EC and E↑ have no requirements.


Data used to define the different factors:

- **Climate Data:** To determine the climate data methodology of the climate zones.
- **Season of the year:** The determination of the season is based on the “Heating and Cooling degree days”.
- **Heat Recovery Simulation:** The simulations were hourly and all over the year. Two situations were made- Dry system with temperature control; Wet system with enthalpy control.
- **Temperature design reference:** The reference dry temperature and dew-point temperature derivate from ASHRAE 2013 data (summer criteria 2)



There are many components to be optimised in an AHU:

- Recovery system
- Fans
- Motors
- Frequency inverters
- Pressure drops
- Velocity
- Size
- External issues
- Etc.



Example: The Impact of The Pressure Drop

If we could reduce the pressure drop in the AHU by 1 Pa:

Data: 1 m³/s, 1 Pa, 3000 h, 13.5 INR/kWh

Energy Saving Result: 67.5 INR/Year, Not much ?

Another example:

Data: 10 m³/s, 100 Pa, 8760 h, 13.5 INR /kWh

Energy Saving Result: 1,97,000 INR/Year

$$P = \frac{\Delta p_t * q}{\eta} * 10^{-3} kW$$

Summary: The pressure drop has a huge impact on the electricity consumption

Estimation of excess electricity consumption


Actual internal resistance of the system higher by 80 Pa (Δp)

Redundant fan power consumption:

$$P = q \cdot \Delta p / \eta = 2.78 \text{ m}^3/\text{s} \cdot (80 \text{ Pa} / 0.6) = 370 \text{ W}$$

Excess annual electricity consumption (supply + exhaust)

$$E = 2 \cdot 0.37 \text{ kW} \cdot 8760 \text{ h} \approx 6\,482 \text{ kWh}$$



Why is This Important For Us ?

Where can we reduce the energy consumption in an office building ?

■ If we improve/change:

- | | | |
|----------------------------|-----------|----------------------------------|
| – Heavier building | +100 mm | :benefit ~ -1 kWh/m ² |
| – More insulation | +200 mm | :benefit ~ -3 kWh/m ² |
| – Better windows (U-value) | 1.4 > 1.0 | :benefit ~ -5 kWh/m ² |

■ Lets look at the Air handling unit

- | | | |
|-------------------|---------------|---|
| Low speed AHU | 2.5 > 1.6 m/s | :benefit ~ -7 kWh/m² |
| Better efficiency | 60% > 85% | :benefit ~ -16 kWh/m² |


A huge potential in our line of business !



AHU Life Cycle Cost Analysis

The Life Cycle Costs of an Air Handling Unit



- If we are looking at the total costs for an air handling unit during its lifetime, the impact of the energy costs are huge
- Aprox. 80-90% of the total costs are related to costs for energy (electricity, heating and cooling)
- Today it has become more and more important to be able to make LCC (life cycle costs) analyses for air handling units



The Life Cycle Costs of an Air Handling Unit

$$LCC = \text{Basic investment} + LCC_{\text{energy}} + LCC_{\text{maintenance}} + LCC_{\text{environment}} - \text{recycling value}$$


- The largest part of the total costs for the air handling unit is naturally the LCC_{energy}
- Therefore FlaktGroup has adopted an LCC_E - module (optional Basic investment) in the product selection program for AHU's




Influences of the LCC Calculation

Component issues:

- Fan efficiency
- Motor efficiency
- Frequency Inverter efficiency
- Pump efficiency
- Energy recovery efficiency
- The relation between the energy efficiency and the pressure loss of the recuperer
- Pressure losses of other components as filters, dampers, silencers, humidifiers, coils etc...





FläktGroup

Selection tool for LCC calculation

FläktGroup

HOME PROJECTS

+ NEW UNIT SAVE AS

View Modify

Energy

Calculation model: FläktGroup model

Currency: INR

Climate data

☒ Specify climate data

(3) Average year temperature/moisture: 25.9 / 20.1 °C, °C wb

(5) Year highest temperature/moisture: 44.9 / 27.1 °C, °C wb

(4) Normal temperature, summer: 41 °C

(2) Normal temperature, winter: 8.6 °C

(1) Year lowest temperature/moisture: 5.6 / 5.2 °C, °C wb

Temperatures

Winter temperature/moisture: 21 / 9.6 °C, °C wb

Summer temperature/moisture: 23 / 11.5 °C, °C wb

Supply air temperature / Moisture: 21 / 9.6 °C, °C wb

Exhaust air temperature / Moisture: 22 / 12.1 °C, °C wb

Cooling calculation: To temperature

☐ Outdoor temp. compensation

Operation

Day operation: 7 days/week, 16 hours/day, 100% air flow, 0% return air

☒ Night operation: 0 days/week, 6 hours/day, 30% air flow, 0% return air

Temp. adjust: 2 °C

☒ Variable flow

Outdoor temperature: -15 °C

Air flow: 60 %

Energy calculation

☒ Energy cost: Energy price: 0.5 INR/kWh

☒ CO₂ - emission: CO₂ / energy unit: 243 g/kWh

☒ Investment: Cost for installed capacity: 0 INR/kW

Economy

☐ Energy - economy

Cancel Calculate >>

Energy

Calculation model: FläktGroup model

Currency: INR

Climate data

☐ Specify climate data

India

NEW DELHI

Average year temperature/moisture: 25.9 / 20.1 °C, °C wb

Temperatures

Winter temperature/moisture: 21 / 9.6 °C, °C wb

Summer temperature/moisture: 23 / 11.5 °C, °C wb

Supply air temperature / Moisture: 21 / 9.6 °C, °C wb

Exhaust air temperature / Moisture: 22 / 12.1 °C, °C wb

Cooling calculation: To temperature

☐ Outdoor temp. compensation

Operation

Day operation: 7 days/week, 16 hours/day, 100% air flow, 0% return air

☐ Night operation

☐ Variable flow

Energy calculation

☒ Energy cost: Energy price: 0.5 INR/kWh


☐ CO₂ - emission


☐ Investment

Economy

☐ Energy - economy

Cancel Calculate >>





Airflow (CFM) 8000

Esp (Pa) 300

Location Delhi

Energy

Calculation model: FläktGroup model

Currency: INR

Climate data

☒ Specify climate data

(3) Average year temperature/moisture: 25.9 °C, 20.1 °C wb

(5) Year highest temperature/moisture: 44.9 °C, 27.1 °C wb

(4) Normal temperature, summer: 41 °C

(2) Normal temperature, winter: 8.6 °C

(1) Year lowest temperature/moisture: 5.6 °C, 5.2 °C wb

Temperatures

Winter: 21 °C, 9.6 °C wb

Summer: 23 °C, 11.5 °C wb

Supply air temperature / Moisture: 22 °C, 12.1 °C wb

Exhaust air temperature / Moisture: 24 °C, 16.8 °C wb

To temperature: [dropdown]

☐ Outdoor temp. compensation

Operation

Day operation: 7 days/week, 16 hours/day, 100% air flow, 0% return air

☐ Night operation

☐ Variable flow

Energy calculation

☒ Energy cost: 0.5 INR/kWh

☐ CO₂ - emission

☐ Investment


Economy

☐ Energy - economy

Energy Class


A+

Annual energy recovery		
Heat recovery	23072	kWh
Cooling recovery	321790	kWh
Temp. rise in supply air fan	4145	kWh
Annual additional energy		
Heating	331	kWh
Cooling	56335	kWh
Supply air fan	17968	kWh
Exhaust air fan	17318	kWh
Other Equipment	596	kWh
Annual energy cost		
Heating	166	INR
Cooling	73236	INR
Supply air fan	287488	INR
Exhaust air fan	277088	INR
Other Equipment	9536	INR
Total	647513	INR




A


Annual energy recovery		
Heat recovery	21587	kWh
Cooling recovery	274777	kWh
Temp. rise in supply air fan	4829	kWh
Annual additional energy		
Heating	829	kWh
Cooling	67518	kWh
Supply air fan	21971	kWh
Exhaust air fan	21746	kWh
Other Equipment	596	kWh
Annual energy cost		
Heating	414	INR
Cooling	87773	INR
Supply air fan	351536	INR
Exhaust air fan	347936	INR
Other Equipment	9536	INR
Total	797196	INR



C

Annual energy recovery		
Heat recovery	18951	kWh
Cooling recovery	229668	kWh
Temp. rise in supply air fan	5177	kWh
Annual additional energy		
Heating	998	kWh
Cooling	71740	kWh
Supply air fan	24819	kWh
Exhaust air fan	23842	kWh
Other Equipment	309	kWh
Annual energy cost		
Heating	499	INR
Cooling	93262	INR
Supply air fan	397104	INR
Exhaust air fan	381472	INR
Other Equipment	4944	INR
Total	877281	INR





Airflow (CFM)	8000
Esp (Pa)	300
Location	Delhi


Summary:

Bigger AHU:

- Higher investment cost
- Lower air velocity
- More recovery
- More efficient fans
- Short pay back

FläktGroup		Energy Class		
		A+	A	C
Electric Energy (Fans)	kWh/a	35286	43717	45785
Heating energy (Heating Coil)	kWh/a	331	829	608
Cooling energy (cooling coil)	kWh/a	56335	67518	66883
Other Equipment	kWh/a	596	596	595
Total Energy cost	01 Unit (INR/a)	₹ 647,513	₹ 797,196	₹ 893,281
Cost difference to class A+ (INR/a)	01 Unit	-	₹ 149,683	₹ 245,768
Difference after 15* years to class A+ (INR/a)	01 Unit	-	₹ 2,245,245	₹ 3,686,520
Number of AHUs (INR/a)	20 Units	-	₹ 44,904,900	₹ 73,730,400
Price of Air handling unit (INR/)	01 Unit	₹3,037,388	₹2,441,965	₹2,112,882





Airflow (CFM) 12000

Esp (Pa) 300

Location Delhi

Energy

Calculation model: FläktGroup model

Currency: INR

Climate data

☒ Specify climate data

(3) Average year temperature/moisture: Winter 25.9, 20.1; Summer 44.9, 27.1

(5) Year highest temperature/moisture: Winter 8.6, 5.2; Summer 41, 11.5

(4) Normal temperature, summer: 41

(2) Normal temperature, winter: 8.6

(1) Year lowest temperature/moisture: Winter 5.6, 5.2; Summer 23, 11.5

Temperatures

Supply air temperature / Moisture: Winter 21, 9.6; Summer 23, 11.5

Exhaust air temperature / Moisture: Winter 22, 12.1; Summer 24, 16.8

Outdoor temp. compensation: ☐

Operation

Day operation: Days/week 7, Hours/day 16, Air flow [%] 100, Return air [%] 0

Night operation: ☐

Variable flow: ☐

Energy calculation

☒ Energy cost: Heating 0.5, Cooling 1.3, Electricity 16, Reheating 0

CO₂ - emission: ☐

Investment: ☐

Economy


Energy - economy: ☐

Cancel Calculate >>

Energy Class


A+

Annual energy recovery			
Heat recovery	33836	kWh	
Cooling recovery	467954	kWh	
Temp. rise in supply air fan	6274	kWh	
Annual additional energy			
Heating	653	kWh	
Cooling	88298	kWh	
Supply air fan	28627	kWh	
Exhaust air fan	26679	kWh	
Other Equipment	601	kWh	
Annual energy cost			
Heating	326	INR	
Cooling	114787	INR	
Supply air fan	458032	INR	
Exhaust air fan	426864	INR	
Other Equipment	9616	INR	
Total	1009626	INR	




A


Annual energy recovery			
Heat recovery	32739	kWh	
Cooling recovery	437991	kWh	
Temp. rise in supply air fan	7233	kWh	
Annual additional energy			
Heating	869	kWh	
Cooling	96303	kWh	
Supply air fan	32932	kWh	
Exhaust air fan	29131	kWh	
Other Equipment	602	kWh	
Annual energy cost			
Heating	434	INR	
Cooling	125194	INR	
Supply air fan	526912	INR	
Exhaust air fan	466096	INR	
Other Equipment	9632	INR	
Total	1128268	INR	



C

Annual energy recovery			
Heat recovery	31003	kWh	
Cooling recovery	417333	kWh	
Temp. rise in supply air fan	8793	kWh	
Annual additional energy			
Heating	485	kWh	
Cooling	104434	kWh	
Supply air fan	42314	kWh	
Exhaust air fan	35704	kWh	
Other Equipment	607	kWh	
Annual energy cost			
Heating	242	INR	
Cooling	135764	INR	
Supply air fan	677024	INR	
Exhaust air fan	571264	INR	
Other Equipment	9712	INR	
Total	1394007	INR	





Airflow (CFM) 12000





Esp (Pa) 300

Location Delhi

Summary:

Bigger AHU:

- Higher investment cost
- Lower air velocity
- More recovery
- More efficient fans
- Short pay back

		Energy Class		
		A+	A	C
Electric Energy (Fans)	kWh/a	55306	62063	78018
Heating energy (Heating Coil)	kWh/a	653	869	485
Cooling energy (cooling coil)	kWh/a	88298	96303	104434
Other Equipment	kWh/a	601	602	607
Total Energy cost	01 Unit (INR/a)	₹ 1,009,626	₹ 1,128,268	₹ 1,394,007
Cost difference to class A+ (INR/a)	01 Unit	-	₹ 118,642	₹ 384,381
Difference after 15* years to class A+ (INR/a)	01 Unit	-	₹ 1,779,630	₹ 5,765,715
Number of AHUs (INR/a)	20 Units	-	₹ 35,592,600	₹ 1,15,143,300
Price of Air handling unit (INR)	01 Unit	₹ 3,558,263	₹ 3,115,165	₹ 2,840,612
				

Thank You!

Mr Arvind Singh
Director
FläktGroup